



KEYNOTES

1. ROUTE A 3/4" CONDUIT WITH (B) #12 TO THE JUNCTION BOX ON THE REFRIGERATION UNIT. MAKE FINAL TERMINATIONS. COORDINATE WITH THE REFRIGERATION UNIT VENDOR.
2. COORDINATE THE EXACT LOCATION OF EQUIPMENT IN THE OFFICE WITH THE OWNER BEFORE OUTLETS AND JUNCTION BOXES ARE ROUGHED IN.
3. STORE SIGNAGE: VERIFY THE EXACT LOCATIONS WITH OWNER. VERIFY ELECTRICAL REQUIREMENTS WITH MANUFACTURERS SPECIFICATIONS. PROVIDE DISCONNECTING MEANS AS REQUIRED BY THE AUTHORITY THROUGH THE LIGHTING CONTACTOR. RE: DETAIL 2/E4.
4. PROVIDE A BLANK JUNCTION BOX FOR THE TELEVISION CABLE. ROUTE 1" CONDUIT TO ABOVE CEILING. TURN 90° WITH BUSHING. COORDINATE WITH EXISTING TRILLS AND OWNER FOR EXACT LOCATIONS.
5. CONNECT EXHAUST HOOD CONTROL PANEL PER MANUFACTURER'S WIRING DIAGRAM TO EXHAUST HOOD TERMINAL STRIP TO EXHAUST FAN ON ROOF. REFER TO MECHANICAL DRAWING FOR ADDITIONAL INFORMATION.
6. DISHWASHER EXHAUST HOOD SHALL BE INTERLOCKED WITH DISH MACHINE "ON/OFF" OPERATION. (EXHAUST FAN "ON" WHILE THE DISHWASHER DOOR IS "OPEN") AND "OFF" /CLOSE OPERATION. CONTRACTOR SHALL INSTALL SWITCH MARKED "DISHWASHER SWITCH" TO OVERRIDE OPERATION MODE.
7. MOUNT LIGHTING AND SIGN CONTACTORS IN THE ELECTRICAL CLOSET AT THE LOCATION SHOWN.
8. ALL WALK-IN COOLER/FREEZER BRANCH CIRCUITS WIRING AND CONDUITS SHALL BE SEALED PER NEC 300.7(A).
9. PROVIDE NON FUSED DISCONNECT SWITCH, 240V, 30A, 2P, NEMA 1, FOR ICE MAKER LOCATION BEFORE ROUGH IN.
10. PROVIDE NON FUSED DISCONNECT SWITCH, 240V, 30A, 2P, NEMA 1.
11. MOUNT SIGN ON THE BALCONY FACE.
12. EVAPORATOR FOR REFRIGERATOR. COORDINATE EXACT ELECTRICAL REQUIREMENTS WITH MANUFACTURER PRIOR TO INSTALLATION. COORDINATE EXACT LOCATION WITH ARCHITECT PRIOR TO INSTALLATION.
13. REMOTE CONDENSER FOR COOLER. COORDINATE EXACT ELECTRICAL REQUIREMENTS WITH MANUFACTURER PRIOR TO INSTALLATION. COORDINATE EXACT LOCATION WITH ARCHITECT PRIOR TO INSTALLATION. REFER TO E3.
14. PROVIDE NON FUSED DISCONNECT SWITCH, 208V, 50A, 3P, NEMA 3R.
15. PROVIDE NON FUSED DISCONNECT SWITCH, 208V, 15A, 3P, NEMA 3R.
16. MOUNT VARIABLE SPEED SWITCHES FOR THE OVEN EXHAUST FANS E1 AND E2 AT THE LOCATION SHOWN JUST ABOVE THE LIGHT SWITCH. REFER TO E4 FOR CONNECTIONS TO THE FANS.
17. DOOR SWITCH PROVIDED WITH DOOR. INSTALLED BY CONTRACTOR.



1/4"=1'-0"
1
POWER PLAN
NORTH

DOCUMENTS FOR:
DOWNTOWN at the GARDENS
GRIMALDI'S PIZZERIA
11701 LAKE VICTORIA GARDENS AVE., STE 3101
PALM BEACH GARDENS, FL 33410

MP
MPW ENGINEERING
Mechanical & Electrical Consulting & Services
110 W. 7TH STREET • SUITE 600 • TULSA, OK 74119
(918) 582-4088 • (918) 582-4087 FAX

GRIMALDI'S
COM. BLDG. OVER PIZZERIA
4000 N. Scottsdale Road, Suite 203
Scottsdale, Arizona 85252
Phone: 408.664.3147 Fax: 408.582.7282

JOHN EDLOW
LICENSED PROFESSIONAL ENGINEER
STATE OF FLORIDA
LICENSE NO. 1582
EXPIRATION DATE 12/31/2012
ENGINEER OF MECHANICAL (E) 015132

This document, and the plans and designs incorporated herein, as an instrument of professional service, is not to be used, in whole or in part, for any other project, without the written authorization of Aaron M. King.

No.	Date	Description

Project: DOWNTOWN at the GARDENS
Drawn: RMY
Approved: RMY
Issue Date: 12/28/2010

Sheet No: E2
ELECTRICAL
POWER PLAN