

MECHANICAL PLAN
SCALE: 1/8"=1'-0"

PRIOR TO SUBMITTING HIS BID, THE CONTRACTOR SHALL DIRECTLY VERIFY ALL EXISTING CONDITIONS AND INFORMATION, INCLUDING THE EXISTING CONDITIONS, AND THE ENGINEER OF ANY DISCREPANCY BETWEEN THESE DOCUMENTS AND THE EXISTING CONDITIONS, AND HE SHALL INCLUDE IN HIS BID TO CORRECT THE SAME AS DIRECTED. THE ENGINEER AND THE ARCHITECT, ARE NOT RESPONSIBLE FOR ANY ADDITIONAL COSTS RESULTING FROM VERIFIABLE EXISTING CONDITIONS DISCOVERED AFTER CONTRACT HAS BEEN AWARDED. NO CHANGES SHALL BE MADE TO THESE PLANS WITHOUT PRIOR APPROVAL FROM THE ENGINEER OF RECORD. ALL CHANGES SHALL BE SUBMITTED FOR REVIEW PRIOR TO INSTALLATION. NOT FOR BID UNTIL PERMIT HAS BEEN ISSUED.

REVISION SET: 03/06/12

FAIR
CONSULTING

1640 N.W. BOCA RATON BLVD.
BOCA RATON, FL 33432
TEL: (561) 391-9292 FAX: (561) 391-9689
CERTIFICATE OF AUTHORIZATION NO. 2B107
HAROLD R. TUSLEB, P.E. LICENSE #19315
URSULA LARATE, P.E. LICENSE #73122
MARTIN WHITLOCK, P.E. LICENSE #53899
E-MAIL: INFO@FAIRCONSULTING.COM


- ALL EXPOSED SUPPLY DUCTWORK SHALL BE DOUBLE WALL, INTERNALLY INSULATED, OR DUCT DUCTWORK (MIN. 1" INSULATION - R-4.1)
- ALL SUPPLY AND RETURN DUCTWORK ABOVE CEILING SHALL BE MINIMUM R-4.1
- FIBERGLASS DUCTWORK
- ALL EXHAUST AND OUTSIDE AIR DUCTWORK SHALL BE SHEET METAL.

KEY NOTES:

① EXISTING EXHAUST DUCT TO BUILDING EXTERIOR. VERIFY EXACT LOCATION IN FIELD.

MECHANICAL PLAN

SCALE: 1/8" = 1'-0"



M1.1

sheet title: MECHANICAL PLAN
file name: 11436 M1.1(2).DWG

project no: 11436
date: 02/14/12
drawn by: AN/CI/AS
checked by: UI

revisions:

1. 03/02/12 ADDENDUM #1
2. 03/06/12 ADDENDUM #2

THESE DRAWINGS ARE FOR THE EXCLUSIVE USE OF GLIDDEN SPINA & PARTNERS, INC. AND MAY NOT BE DUPLICATED, REPRODUCED OR USED IN ANY MANNER WITHOUT THE EXPRESS WRITTEN CONSENT OF GLIDDEN SPINA & PARTNERS, INC. ALL RIGHTS RESERVED.

**TENANT IMPROVEMENTS FOR:
NORTHBIDGE CENTER GYM FACILITY**

515 N. FLAGLER DR., SUITE P-100
WPB, FLORIDA



GLIDDEN • SPINA & PARTNERS
ARCHITECTURE • INTERIOR DESIGN, INC.

PHONE: 561.684.6844 • FAX: 561.684.5594 • E-MAIL: info@gsp-architects.com
1401 FORUM WAY, SUITE 100 • WEST PALM BEACH, FLORIDA 33401
FL License: #AA26001602

Keith M. Spina #AR13419 **Benjamin John Glidden, III #AR6536**