

- 1 REPAIR EXISTING BREAKER WITH NEW BREAKER SHOWN.
- 2 PROVIDE NEW BREAKER SHOWN IN THE EXISTING SPACE.
- 3 REPLACE EXISTING SINGLE POLE BREAKERS WITH NEW MULTIPOLE BREAKER SHOWN.
- 4 EXISTING CIRCUIT BREAKER AND CIRCUIT TO REMAIN.
- 5 ROUTE CIRCUIT THROUGH TIME CLOCK OR PHOTOCELL CONTROLLED CONTINUOUS RELAY 2 1/2" x 3 1/4".
- 6 INSTALL ISOLATED GROUND BUS IN THE EXISTING PANEL.

CONTRACTOR NOTES:

1. FIELD VERIFY EXISTING CONDITIONS PRIOR TO BIDDING
2. REVIEW THE CONTRACT AGREEMENTS WITH THE OWNER AND THE TENANT TO VERIFY EXACTLY THE TENANT CONTRACTORS EXTENT OF WORK AND MATERIALS AND INCLUDE IN THE BID.
3. COORDINATE WITH TENANT AND LANDLORD TO PROVIDE AND MAINTAIN ACCESS TO LANDLORD'S INSTALLED SYSTEMS AND FIELD VERIFY THE EXACT REQUIREMENTS.



PANELBOARD



PANELBOARD

PANELBOARD
SPECIAL NOTES 1

MPW
MPW ENGINEERING,
Mechanical & Electrical Consulting & Services

110 W. 7TH STREET • SUITE 600 • TULSA, OK 74119
(918) 582-4088 • (918) 582-4087 FAX

--	--

[illegible]

E4

Sheet No:

ELECTRICAL
ONE-LINE DIAGRAM
PANEL SCHEDULES

Sheet Title: